



SINGLE FAMILY

Austin City Code Chapter 6-7, June 2009

ECAD Energy Audit Results

For Residence: [4307 AVENUE F AUSTIN, TX, 78751](#)

Audit Date: [5/17/2023](#)

Thank you for complying with the City of Austin's ECAD Ordinance, which requires homeowners to provide these energy audit results to buyers

SAVE THIS FORM! This ECAD audit is valid for 10 years after the audit date.

This audit helps you identify energy efficiency improvements that could lower your monthly energy costs and make your home more comfortable. Austin Energy's Home Performance with ENERGY STAR® program offers rebates and low-interest loans that make these improvements more affordable. Before you begin making any home energy efficiency improvements, be sure to get the latest program details from austinenrgy.com or by calling **512-482-5346**

ENERGY AUDIT SUMMARY

	Action Recommended?	Potential Annual Savings*:
A. Windows and Shading	NO	\$0.00
B. Attic Insulation	NO	\$0.00
C. Air Infiltration and Duct Sealing	NO	\$0.00
D. Heating and Cooling System Efficiency (HVAC)	NO	\$0.00
	Total Annual Savings*:	\$0.00

HOME IMPROVEMENT RECOMMENDATIONS:

Austin Energy recommends the following actions based on the energy audit performed by

● [Vance Acker](#) of [Green Leaf Energy LLC](#) ●

- A. [No windows or shading recommendations.](#)
- B. [No Attic insulation recommendations.](#)
- C. [No air infiltration or duct sealing recommendations.](#)
- D. [No heating and cooling system recommendations.](#)

We appreciate your support of the ECAD ordinance and your efforts to make Austin the most livable city in the country.

DISCLOSURES: Figures are based on an estimate from the average single-family house in Austin (1800 - 2000 sq. ft.) that has made improvements through an efficiency program by Austin Energy or Texas Gas Service. Weather, equipment installation and electric usage will all effect actual savings. There is no guarantee or warranty, either expressed or implied, as to the actual effectiveness, cost or utility savings, if you choose to implement these recommendations. The Energy Conservation Audit and Disclosure is not required to be included in the sales contract nor the Seller's Disclosure form (Texas Real Estate Commission), but instead is a stand-alone requirement of the City of Austin.



SINGLE FAMILY

In support of the City of Austin's Energy
Conservation Audit and Disclosure Ordinance
Austin City Code Chapter 6-7, June 2009

Energy Audit Data

DATA SUMMARY

PROPERTY

Outdoor Temperature F: 83.0

Austin Energy Electric Meter Number: 3231814

Tax Assessor's Property ID: 215900

Requestor Name:

Year Built: 1912

Service Address: 4307 AVENUE F AUSTIN, TX, 78751

Estimated Square Footage: 2166

AUDITOR

Auditor: Vance Acker

Phone Number: (512) 922-7522

Company Name: Green Leaf Energy LLC

Property Audit Date: 5/17/2023

WINDOWS & SHADING

Type(s) of Window(s): Single Pane;Double Pane;Low-e;Skylights

Type(s) of Existing Solar Shading: Vegetation

ATTIC INSULATION

Attic Insulation Type: Spray-Open Cell Foam

Average R-Value: 29

Open Chases(s): No chases in residence.

HEATING & COOLING AIR DUCT SYSTEM

SYSTEM # 1

Condenser Manufacturing Date 2013

HVAC Duct Air Leakage 190.00

Estimated EER 11.5

% Leakage 12

Furnace/AH Manufacturing Date 2006+

Duct System Types(s) Mylar Flex

AFUE [Electric Start] 80%

Enrolled in AE Power Partner Thermostat Program No

AIR INFILTRATION / WEATHERIZATION

Exterior doors: weather-stripped? Yes

Attic access: weather-stripped? No

Plumbing penetrations: sealed? Plumbing penetrations are sealed

ADDITIONAL AUDIT INFORMATION

Domestic Water Heater Type(s): Tankless

Fuel Type: Natural Gas

Type(s) of Toilet(s): 2 Low efficiency toilet(s), 1 High efficiency toilet(s)

PROPERTY IDENTIFICATION

County	Travis	Property ID	215900	Property Type	Single Family	Building Count	1
Meter Number	3231814			Gas Type	Austin I/S Res		
Service Address	4307 AVENUE F AUSTIN, TX, 78751						
					Occupied By	Vacant	
Year Built	1912	Foundation	Pier & Beam	Est. Sq Footage	2166	Avg. Duct Leakage (%)	12
Levels	1	Bedrooms	4	Baths	2.5	Fireplaces	0
Average Attic R-Value	29		Average Wall Height	9			

WINDOWS AND SHADING

Types of Windows	Single Pane;Double Pane;Low-e;Skylights									
Types of Shading	Vegetation									
Windows	S	SW	W	NW	N	NE	E	SE	Skylight	
Needs Shade (sf ft)										
House Shape	Zigzag				Building Front Orientation			W		

APPLIANCES & WATER HEATER

APPLIANCES (Remaining in Home)	'92 or older		'93 or newer				
Refrigerators	0		1	Pool and / or Jacuzzi Pumps	0		
Freezers	0		0	Speed	None		
Clothes Washer	0		1	Pool Pump Timers	0		
Clothes Dryers	Vented Electric	0	1	Water Heaters	1		
Dish Washers			1	WH1	Tankless	Fuel 1	Natural Gas
Range/Stove/Ovens	Gas		1	WH2	None	Fuel 2	None
Inefficient Toilets (> 1.28 gal)	2			Water Heater Timers	1		
Efficient Toilets (<= 1.28 gal)	1						
MISC Lighting	Combination		Solar PV	No	Electric Vehicle Charger	No	
Sprinklers	Yes		Year Installed		Rainwater Collector	No	
Natural Gas Generator	No		Water Saving Devices	Some Installed			

ATTIC INSULATION & AIR INFILTRATION

Roof Type	Pitched	Roof Materials	Shingle	Roof Color	Medium	Total Attic R Value	29
Attic Insulation	Insulation Type		Spray-Open Cell Foam		Secondary Insulation Type	None	
	Square Feet		2166	Inches Deep	8.0	R Value	29
Vaulted Ceiling Insulation	Insulation Type		No Vaulted Ceiling		Secondary Insulation Type	None	
	Square Feet			Inches Deep		R Value	0
Cathedral Ceiling Insulation	Insulation Type		No Cathedral Ceiling				
	Square Feet			Inches Deep		R Value	0
Attic/Knee Wall Insulation Status	Insulated						
No	Radiant Barrier	Radiant Barrier Type		None	Chases	None	
	Plumbing Penetrations Sealed		Yes	Furnace & WH Closet Appropriately Sealed			Yes
	# Exterior Doors	2	# Doors Weather-stripped		2	Whole House Fan	None
	# Conditioned Stair Boxes/Hatches	0	# Insulated	0	# Weather-stripped	0	

HEATING AND COOLING

Unit # 1	Zone Description	Whole house	Duct System	Mylar Flex
	Estimated Square Footage (Zone)	2166	Duct Locations	Sealed Attic
	Cooling Type	Central Air	Duct Condition	Good
	Thermostat	WiFi	R-Value	R-6
	Condenser Mfg Year	2013	Return Air Sq In	840.0
	Estimated EER	11.5	Return Plenum Properly Sealed	Yes
	Estimated Condenser BTUs	[4.0] 48,000 BTU	Grille Type	Stamped
	Tonnage from Mfg Spec	4.0	Target CFM	1600
	Tonnage from Est Sq Ft	4	Estimated CFM	1680.00
	Sqft Per Ton	541.5	Did Not Reach Pressure	False
	Heating Type	Central Heat	Pressure Test Leakage CFM	190.00
	Fuel Type	Gas	% Leakage	12
	Furnace/Air Handler Location	Inside House - Sealed Attic	Supply Air Reading	
	Air Handler Type	Horizontal	Return Air Reading	
	Furnance Mfg Date	2006+	Delta T	0.0
	Estimated Furnance BTUs	[4.0] 70K	AFUE	[Electric Start] 80%

NOTES & INSTRUCTIONS